



| Model (Duplex) | Typical | RO | Max Flow To Drain | Pipe Size | | Media | Mineral Tank | | Installation | | | Shipping Weight | Operating Weight |
|-------------------|------------------|-------|----------------------|-----------|-------|----------|--------------|--------|--------------|-------|-------|--------------------|---------------------|
| | System Flow Rate | | | Service | Drain | Per Tank | Diameter | Height | Height | Depth | Width | | |
| | USGPM | USGPM | USGPM | in | in | CF | in | in | in | in | in | | |
| | l/s | l/s | l/s | mm | mm | m3 | mm | mm | mm | mm | mm | kg | kg |
| CW MM14-1" | 20 | 16 | 10 | 1" | 1" | 2.65 | 14 | 65 | 79 | 20 | 40 | 826 | 1,626 |
| | 1.26 | 1.00 | 0.64 | 25 | 25 | 0.08 | 356 | 1,651 | 2,007 | 508 | 1,016 | 376 | 738 |
| CW MM16-1" | 28 | 22 | 15 | 1" | 1" | 3.5 | 16 | 65 | 79 | 22 | 44 | 1,026 | 2,026 |
| | 1.76 | 1.38 | 0.95 | 25 | 25 | 0.1 | 406 | 1,651 | 2,007 | 559 | 1,118 | 466 | 919 |
| CW MM18-1" | 34 | 26 | 15 | 1" | 1" | 4.4 | 18 | 65 | 79 | 24 | 48 | 1,302 | 2,502 |
| | 2.14 | 1.64 | 1.26 | 25 | 25 | 0.13 | 475 | 1,651 | 2,007 | 610 | 1,220 | 591 | 1,135 |



RAW WATER REGENERATION PIPING SHOWN



- LEGEND:
- ISOLATION VALLVE
 - BYPASS VALVE
 - PRESSURE GAUGE & SAMPLE POINT
 - OPEN DRAIN
 - VACUUM BREAKER
 - RAW WATER LINES
 - FILTERED/SOFTENED WATER LINES
 - WATER TO OPEN DRAIN
 - TREATED WATER LINES
 - ELECTRONIC BALL VALVE
 - UNION OR FLANGE
 - DIAPHRAGM VALVE

NOTES

- DUPLEX FILTER, CALENDAR CLOCK INITIATED, SERIES REGENERATED SYSTEM.
- FILTER EQUIPPED WITH 1" VALVES WITH ELECTRONIC CONTROLLER.
- MAXIMUM RECOMMENDED SYSTEM PRESSURE IS 100 PSI (690 kPa) AND MINIMUM INLET PRESSURE IS 40 PSI.
- MAXIMUM RECOMMENDED SYSTEM TEMPERATURE IS 100 °F (38 °C).
- REQUIRES 120 VOLT, 1 PHASE, 60 Hz ELECTRICAL POWER.
- ALL EXTERNAL PIPING, FITTINGS, AND VALVES SHOWN BY BROKEN LINES ARE SUPPLIED BY OTHERS.
- MINERAL TANKS AND MEDIA ARE NSF APPROVED.
- DUE TO SLIGHT EXPANSION AND CONTRACTION OF MINERAL TANK, PIPING MUST BE DESIGNED TO ALLOW SOME MOVEMENT. AS WELL AS BE PROTECTED FROM VACUUM. FLEX CONNECTORS AND A VACUUM BREAKER MAY BE REQUIRED. FAILURE TO INSTALL EITHER OF THEM OR IMPROPERLY INSTALL THEM MAY VOID THE WARRANTY.
- SYSTEM MUST BE INSTALLED TO COMPLY WITH ALL FEDERAL, STATE, PROVINCIAL, & LOCAL CODES.
- FLOOR DRAINS MUST BE SIZED TO CARRY THE MAX. LISTED FLOW TO DRAIN.
- REFER TO THE INSTALLATION AND OPERATION MANUAL FOR FURTHER DETAILS.
- USE PROPER UNION OR FLANGE FOR THE PIPE CONNECTION TO VALVE FOR EASY MAINTENANCE.
- MEDIA BED CONSISTS OF NSF APPROVED ANTRAFILT, FINE FILTER SAND FINE & COARSE GARNET ON A GRADED SUPPORT BED.

CW MULTIMEDIA FILTER 1" DUPLEX SYSTEM

THIS DOCUMENT CONTAINS INFORMATION WHICH IS PROPRIETARY TO CANATURE WATERGROUP. THE REPRODUCTION, TRANSFER, OR OTHER EXPLOITATION OF ANY INFORMATION CONTAINED HEREIN IS NOT PERMITTED WITHOUT PRIOR WRITTEN APPROVAL OF CANATURE WATERGROUP. THE MANUFACTURER RESERVES THE RIGHT TO MAKE PRODUCT REVISIONS, WHICH MAY DEVIATE FROM THE SPECIFICATIONS AND DESCRIPTIONS STATED HEREIN WITHOUT OBLIGATION TO CHANGE PREVIOUSLY MANUFACTURED PRODUCTS OR TO NOTE THE CHANGE.

| | | |
|---------------|-----------------|-----------|
| Project _____ | Date 10-18-2017 | Rev _____ |
| | Dwg # CW MM1D | 0 |