


Model (Single)	Typical	Peak	RO	Max Flow To Drain	Pipe Size		Media	Mineral Tank		Installation			Shipping Weight	Operating Weight		
	Max. Recommended Flow Rates				Service	Drain	Per Tank	Diameter	Height	Height	Depth	Width				
	USGPM	USGPM	USGPM		USGPM	in	in	CF	in	in	in	in			lbs	lbs
	l/s	l/s	l/s		l/s	mm	mm	m3	mm	mm	mm	mm			mm	kg
CW NX14-1"	10	15	8	12	1"	1"	2.75	14	65	79	20	20	343	743		
	0.63	0.95	0.5	0.76	25	25	0.078	356	1,651	2,007	508	508	156	337		
CW NX16-1"	14	20	11	15	1"	1"	3.5	16	65	79	22	22	429	929		
	0.88	1.26	0.69	0.95	25	25	0.1	406	1,651	2,007	559	559	194	421		
CW NX18-1"	17	26	13	20	1"	1"	4.5	18	65	79	24	24	544	1,144		
	1.071	1.64	0.819	1.26	25	25	0.127	475	1,651	2,007	610	610	247	519		

INLET OUTLET



RAW WATER REGENERATION PIPING SHOWN

NOTES

- SINGLE FILTER, CALENDAR CLOCK INITIATED.
- FILTER EQUIPPED WITH 1" VALVES WITH ELECTRONIC CONTROLLER.
- MAXIMUM RECOMMENDED SYSTEM PRESSURE IS 100 PSI (690 kPa) AND MINIMUM INLET PRESSURE IS 40 PSI.
- MAXIMUM RECOMMENDED SYSTEM TEMPERATURE IS 100 °F (38 °C).
- REQUIRES 120 VOLT, 1 PHASE, 60 Hz ELECTRICAL POWER.
- ALL EXTERNAL PIPING, FITTINGS, AND VALVES SHOWN BY BROKEN LINES ARE SUPPLIED BY OTHERS.
- MINERAL TANKS AND MEDIA ARE NSF APPROVED.
- DUE TO SLIGHT EXPANSION AND CONTRACTION OF MINERAL TANK, PIPING MUST BE DESIGNED TO ALLOW SOME MOVEMENT. AS WELL AS BE PROTECTED FROM VACUUM. FLEX CONNECTORS AND A VACUUM BREAKER MAY BE REQUIRED. FAILURE TO INSTALL EITHER OF THEM OR IMPROPERLY INSTALL THEM MAY VOID THE WARRANTY.
- SYSTEM MUST BE INSTALLED TO COMPLY WITH ALL FEDERAL, STATE, PROVINCIAL, & LOCAL CODES.
- FLOOR DRAINS MUST BE SIZED TO CARRY THE MAX. LISTED FLOW TO DRAIN.
- REFER TO THE INSTALLATION AND OPERATION MANUAL FOR FURTHER DETAILS.
- USE PROPER UNION OR FLANGE FOR THE PIPE CONNECTION TO VALVE FOR EASY MAINTENANCE.
- MEDIA BED CONSISTS OF NSF APPROVED, NEXTSAND® ON A GRADED SUPPORT BED

CW NEXTSAND FILTER 1" SINGLE SYSTEM

THIS DOCUMENT CONTAINS INFORMATION WHICH IS PROPRIETARY TO CANATURE WATERGROUP. THE REPRODUCTION, TRANSFER, OR OTHER EXPLOITATION OF ANY INFORMATION CONTAINED HEREIN IS NOT PERMITTED WITHOUT PRIOR WRITTEN APPROVAL OF CANATURE WATERGROUP. THE MANUFACTURER RESERVES THE RIGHT TO MAKE PRODUCT REVISIONS, WHICH MAY DEVIATE FROM THE SPECIFICATIONS AND DESCRIPTIONS STATED HEREIN WITHOUT OBLIGATION TO CHANGE PREVIOUSLY MANUFACTURED PRODUCTS OR TO NOTE THE CHANGE.

Project _____	Date 10-18-2017	Rev
	Dwg # CW NX1S	0